

Operating instructions AS-i SmartLine module

AC2250 AC2251 AC2252 AC2254 AC2257 AC2261 AC2264 AC2266 AC2267

Contents

1	1.2 Safety symbol on the device	3 3 3
2	Safety instructions	4
3	Intended use	5
4	4.1 Installation location 4.2 Installation of the device 4.3 Identical devices mounted side by side 4.4 Deratings for side by side mounting of identical devices 4.5 Side by side mounting of different devices	6 6 6 6 7 8 9
5	Electrical connection	001123344
6	Set-up / addressing	
7	Operating and display elements 1 7.1 Operation / LEDs 1 7.2 Scale drawing 1	6
8	Maintenance, repair and disposal	8 8 8

1 Preliminary note

You will find instructions, technical data, approvals, accessories and further information using the QR code on the unit / packaging or at www.ifm.com.

1.1 Symbols used

- √ Requirement
- Instructions
- Reaction, result
- [...] Designation of keys, buttons or indications
- → Cross-reference
- Important note
 - Non-compliance may result in malfunction or interference.
- Information
 Supplementary note

1.2 Safety symbol on the device



Safety symbol on the device:

▶ Adhere to the operating instructions for the safe operation of the unit.

1.3 Warnings used

ATTENTION

Warning of damage to property



CAUTION

Warning of personal injury

> Slight reversible injuries may result.



WARNING

Warning of serious personal injury

Death or serious irreversible injuries may result.

2 Safety instructions

- The unit described is a subcomponent for integration into a system.
 - The system architect is responsible for the safety of the system.
 - The system architect undertakes to perform a risk assessment and to create documentation in accordance with legal and normative requirements to be provided to the operator and user of the system. This documentation must contain all necessary information and safety instructions for the operator, the user and, if applicable, for any service personnel authorised by the architect of the system.
- Read this document before setting up the product and keep it during the entire service life.
- The product must be suitable for the corresponding applications and environmental conditions without any restrictions.
- Only use the product for its intended purpose (→ Intended use).
- If the operating instructions or the technical data are not adhered to, personal injury and/or damage to property may occur.
- The manufacturer assumes no liability or warranty for any consequences caused by tampering with the product or incorrect use by the operator.
- Installation, electrical connection, set-up, operation and maintenance of the product must be carried out by qualified personnel authorised by the machine operator.
- Protect units and cables against damage.
- Replace damaged units, otherwise the technical data and safety will be impaired.

3 Intended use

- The devices act as digital input and output modules in the AS-i network. They connect max. 4 sensors (2-wire or 3-wire sensors) and max. 4 actuators each with the AS-i master.
- Actuator outputs as high-side semiconductor outputs with overload/short-circuit protection.
- In the control cabinet in an industrial environment (indoors) as a permanently installed device with supply from SELV/PELV according to the technical data.

Operation by trained, authorised specialist personnel due to protection class IP20.

AC2250: 4 digital inputs, sensor supply from AS-i

AC2251: 4 digital inputs / 4 digital outputs (transistor), sensor supply from AS-i

AC2252: 4 digital outputs (transistor)

AC2254: 4 digital inputs, sensor supply from AUX

AC2257: 4 digital inputs / 4 digital outputs (transistor), sensor supply from AUX

AC2261: 4 digital inputs / 4 digital outputs (transistor), sensor supply from AS-i

AC2264: 4 digital inputs / 3 digital outputs (transistor), sensor supply from AS-i

AC2266: 4 digital inputs / 3 digital outputs (transistor), sensor supply from AUX

AC2267: 4 digital inputs / 4 digital outputs (transistor), sensor supply from AUX


4 Installation


4.1 Installation location

To ensure correct operation, install the device in a housing that can only be opened using a tool or in a locked control cabinet (both protection rating IP 54 or higher) as an enclosure in accordance with EN61010-1.

4.2 Installation of the device

▶ Mount the device on a 35 mm DIN rail.





► Leave enough space (≥ 50 mm) between the device and the top and bottom of the control cabinet to enable air circulation and to avoid excessive heating.

4.3 Identical devices mounted side by side







Fig. 1: Identical devices mounted side by side


4.4 Deratings for side by side mounting of identical devices

When identical devices are mounted next to each other, derating according to the following tables applies:










4.5 Side by side mounting of different devices

ATTENTION

If units are mounted side by side, inadmissible heating may occur between the units.

- ▶ Take into account the internal heating of all devices when mounting different devices side by side and observe the environmental conditions for each device.

4.6 Removing the device



4.7 Installation of the sensors

► Follow the manufacturer's installation instructions.

5 Electrical connection

5.1 General wiring information

- Disconnect the device from the mains supply before installation; if necessary, also disconnect any independently supplied input / output load circuits.
 - ▶ Observe the national and international regulations for the installation of electrical equipment.
- AS-i / AUX only permissible as SELV / PELV.
 - ▶ Do not use unconnected terminals which are not shown in the drawing as support point terminals.

Touchable surfaces of the unit are insulated to the AS-i / AUX circuits with basic insulation according to IEC 61010-1 (mains circuit of overvoltage category II up to 300 V nominal mains voltage).

This does not apply to connection areas and cooling openings (IP20)


The AS-i / AUX circuits are insulated from each other with basic insulation according to IEC 61010-1 (secondary circuit with max. 32 V DC, supplied from the mains circuit up to 300 V of overvoltage category II).


The external wiring has to be carried out in a way that ensures the required separation from other circuits.

- AC2250, AC2251, AC2261, AC2264
 - Do not connect the terminals I1...I4 und I+, I- to external potential.
- The switch-on and switch-off capacity for triggering solenoids is rated up to 20 W (according to IEC 60947-5-2, utilisation category DC-13).

5.2 Deratings for separately mounted devices

Observe the derating of the current rating depending on the ambient temperature according to the following tables:





5.3 Wiring

5.3.1 Digital input and output modules AC2251, AC2257, AC2261 and AC2267




Fig. 2: Wiring




Fig. 3: Terminal connection

I-: sensor supply 0 V I+: sensor supply +24 V AC2251, sensor supply via AS-i

AC2261:

AC2257, sensor supply via AUX

AC2267:

O-: actuator switching output 0 V I1...I4: switching input sensor 1....4 O1...O4: switching output actuator 1....4

A+: AS-i + A-: AS-i -

E+: external voltage supply (AUX) for sensors (AC2257,

AC2267) / actuators +24 V

E-: external voltage supply (AUX) for sensors (AC2257,

AC2267) / actuators +0 V

5.3.2 Digital input modules AC2250 and AC2254




Fig. 4: Wiring
1: only AC2254




Fig. 5: Terminal connection

I-: sensor supply 0 V I+: sensor supply +24 V AC2250: sensor supply via AS-i AC2254: sensor supply via AUX I1...I4: switching input sensor 1....4

A+: AS-i + A-: AS-i -

E+: external voltage supply (AUX) for sensors +24 V (only

AC2254)

E-: external voltage supply (AUX) for sensors +0 V (only

AC2254) not used

5.3.3 Digital output module AC2252




Fig. 6: Wiring




Fig. 7: Terminal connection

O-: actuator switching output 0 V O1...O4: switching output actuator 1....4

A+: AS-i + A-: AS-i -

E+: external voltage supply (AUX) for actuators +24 V
E-: external voltage supply (AUX) for actuators +0 V

5.3.4 Digital input and output modules AC2264 and AC2266




Fig. 8: Wiring




Fig. 9: Terminal connection

I-: sensor supply 0 V
I+: sensor supply +24 V
AC2264: sensor supply via AS-i
AC2266: sensor supply via AUX
O-: actuator switching output 0 V
I1...I4: switching input sensor 1....4
O1...O3: switching output actuator 1....3

A+: AS-i + A-: AS-i -

E+: external voltage supply (AUX) for sensors (AC2266) /

actuators +24 V

external voltage supply (AUX) for sensors (AC2266) /

actuators +0 V

res reserved

5.4 Connection technology

ATTENTION

No IP20 protection without connector.

> Cover unused connectors with terminals.

▶ Observe IP 20.

▶ Strip the insulation from the connection cables to 10 mm.

5.5 Connection accessories

The device is supplied without connector.

5.6 AUX supply / fuse

Only for connection with an isolating transformer with a UL approved max. 10 A upstream fuse at AUX (E+).

Alternatively, a class 2 power supply can be used to supply AUX.

Alternatively, an energy-limited circuit according to UL61010 can be used to supply AUX.

▶ Please note the technical data concerning the AUX supply.

ন The maximum cable length is 30 m.

6 Set-up / addressing

The address is set to 0 at the factory.

6.1 Addressing with the AC1154 addressing unit

When mounted and wired, the module can be addressed with the addressing cable (E70213) via the integrated addressing interface.


If a slave is used in combination with a master of the new generation (version 2.1), it is possible to select an address between 1A and 31B with the AC1154 addressing unit.

If a slave with the ID code "A" (extended address mode possible) is used in combination with a master of the 1st generation (version 2.0), the parameter P3 must be 1 and the output bit D3 must be 0.* The output bit D3 must not be used.

An address between 1A and 31A must be assigned to this slave.

* Default setting

7 Operating and display elements




1:	connector with cage clamps	LED 1-1: switching status indication for sensor inputs I1I4 (except AC2252)
2:	panel for labelling	LED 2-1: AS-i, FAULT, AUX (except for AC2250)
3:	addressing socket	LED 3-1: switching status indication for actuator outputs O1O4 (except AC2250 and AC2254)
4:	DIN rail mounting	

7.1 Operation / LEDs

LED 1 yellow LED lights:	inputs (I1I4) switched
LED 2 AS-i green lights:	AS-i voltage supply OK
LED 2 FAULT red lights:	AS-i communication error, slave does not participate in the "normal" exchange of data, e.g. slave address 0
LED 2 FAULT red flashes:	peripheral fault, e.g. sensor supply / output overloaded or shorted
LED 2 AUX green lights:	external voltage supply ok
LED 3 yellow LED lights:	relay output (O1O3) / (O1O4) switched

7.2 Scale drawing



8 Maintenance, repair and disposal

8.1 Maintenance

The unit is maintenance-free.

8.2 Cleaning the housing surface

- ▶ Disconnect the device.
- ▶ Clean the device from dirt using a soft, chemically untreated and dry cloth.
- Micro-fibre cloths without chemical additives are recommended.

8.3 Repair

lacktriangle The device must only be repaired by the manufacturer. Observe the safety instructions (\rightarrow 2 Safety instructions).

8.4 Disposal

▶ Dispose of the unit in accordance with the national environmental regulations.